

Lafayette City-Parish Consolidated Government may, at its own discretion, choose to allocate only portions of certain pollutant parameters listed in the tables below to specific Industrial Users. The Lafayette City-Parish Consolidated Government retains full authority to establish limits in the Industrial Waste Permits that are lower than those listed herein. The Lafayette City-Parish Consolidated Government retains full authority, upon the approval of the POTW's Control Authority, to increase these local limits; and, establish local limits for additional pollutant parameters not herein listed. Limits imposed on Industrial Users may be in the form of (but not limited to); daily maximums, pounds per day (#/day), pounds per week (#/week), instantaneous limits, and/or specific period (such as monthly) averages. The limits listed below apply at the point where the wastewater is discharged to the POTW.

1) South Sewage Treatment Plant

<u>Pollutant Parameter</u>	<u>Daily Maximum (Mg/L)</u>
Total Mercury	0.14
Total Cadmium	0.97
Total Selenium	< 1.00
Total Arsenic	2.88
Total Silver	3.93
Total Chromium	< 5.00
Total Lead	< 5.00
Total Molybdenum	5.13
Total Cyanide	7.07
Total Zinc	8.73
Total Nickel	18.68
Total Copper	30.05
Total Barium	< 100.00

2) East Sewage Treatment Plant

<u>Pollutant Parameter</u>	<u>Daily Maximum (Mg/L)</u>
Total Mercury	< 0.20
Total Molybdenum	0.50
Total Cadmium	< 1.00
Total Selenium	< 1.00
Total Arsenic	2.30
Total Cyanide	3.13
Total Chromium	< 5.00
Total Lead	< 5.00
Total Silver	< 5.00
Total Nickel	7.95
Total Zinc	19.07
Total Copper	23.58
Total Barium	< 100.00

3) Ambassador Caffery Sewage Treatment Plant

<u>Pollutant Parameter</u>	<u>Daily Maximum (Mg/L)</u>
Total Mercury	0.10
Total Arsenic	0.77
Total Cadmium	< 1.00
Total Selenium	< 1.00
Total Cyanide	1.27
Total Molybdenum	2.06
Total Silver	2.37
Total Chromium	< 5.00
Total Lead	< 5.00
Total Nickel	6.69
Total Copper	9.34
Total Zinc	9.51
Total Barium	< 100.00

4) Northeast Sewage Treatment Plant

<u>Pollutant Parameter</u>	<u>Daily Maximum (Mg/L)</u>
Total Mercury	0.13
Total Cadmium	< 1.00
Total Selenium	< 1.00
Total Silver	1.24
Total Cyanide	2.70
Total Lead	2.79
Total Molybdenum	2.79
Total Arsenic	2.80
Total Chromium	< 5.00
Total Zinc	6.90
Total Copper	28.65
Total Nickel	28.73
Total Barium	< 100.00