





# Lafayette Utilities System

(C2 Continued)

other associated material and equipment which the customer must provide to insure continuity of service. Such agreements may promote adherence to such standards, and provide terms for billing the customer for system-provided maintenance services on customer-owned facilities and other related terms and conditions.

## **Power factor adjustment:**

Power factor adjustments will be made when it has been determined that a customer's average monthly power factor is below eighty percent (80%). For such customers, the metered demand kW will be adjusted by dividing it by the actual power factor, and then multiplying the result by 0.80.